



Owner:  
HINDALCO INDUSTRIES LIMITED  
Ahura Centre, 1st Floor, B Wing, Mahakali Caves Road, Andheri (East), Mumbai - 400 093, India



EPCM Contractor:  
W. L. GORE & ASSOCIATES (Pacific) Pte, Ltd. India Branch  
703, A-Wing, 215 Atrium, Andheri Kurla Road, Mumbai 400059, India



Nominated Subcontractor - Engineering, Quality Control, Supervision:  
SMARTLuth Solution and Service Pvt. Ltd.  
Unit No: 503, 5th Floor, ECO Centre, EM-4 Sector-V, Salt Lake City, Kolkata - 700091, India

## Hindalco Renusagar U5 1 x 80 MW PF Captive Power Plant

### Flue Gas Desulfurization Project (FGD) with GORE™ SO<sub>2</sub> Control System

### FGD-Technical Specification with Equipment Sizing

ISSUED FOR	APPROVAL <input checked="" type="checkbox"/>	INFORMATION <input type="checkbox"/>	MANUFACTURING <input type="checkbox"/>	CONSTRUCTION <input type="checkbox"/>	AS-BUILT <input type="checkbox"/>
------------	--	--------------------------------------	--	---------------------------------------	-----------------------------------

00	10/03/2022	First Submission	S.Das	S.Chakraborty	M.Deb
Rev.	Date	Description of revision	Prepared	Checked	Approved

Hindalco Renusagar U5 1 x 80 MW PF Captive Power Plant

Flue Gas Desulfurization Project (FGD) with GORE™ SO<sub>2</sub> Control System

### FGD-Technical Specification with Equipment Sizing

Doc. No.: S21001 - TS01 - 05HSD - 227201

Gore Doc. No.:  
RPDU5.PG.001

page

GORE Job No.: RPDU5

Rev. : 00

File: FGD- Technical Specification with Equipment Sizing

This document is a property of W.L. GORE & ASSOCIATES (Pacific) Pte, Ltd. and it may contain trade secrets or privileged, undisclosed or otherwise confidential information. If you have received this document in error, you are hereby notified that any review, copying or distribution of it is strictly prohibited.



Owner:  
HINDALCO INDUSTRIES LIMITED  
Ahura Centre, 1st Floor, B Wing, Mahakali Caves Road, Andheri (East), Mumbai - 400 093, India



EPCM Contractor:  
W. L. GORE & ASSOCIATES (Pacific) Pte, Ltd. India Branch  
703, A-Wing, 215 Atrium, Andheri Kurla Road, Mumbai 400059, India

Hindalco Renusagar U5 1 x 80 MW PF Captive Power Plant  
Flue Gas Desulfurization Project (FGD) with GORE™ SO<sub>2</sub> Control System

### FGD-Technical Specification with Equipment Sizing

Client Doc.: S21001-TS01 -05HSD- 227201  
GORE Doc.: RPDU5.PG.001  
Rev.: 00 dated 10/03/2022  
File: FGD- Technical Specification with Equipment Sizing

#### Intent:

Flue Gas De-sulphurisation system is introduced on Unit # 5- 1 x 80 MWe of Coal Fired Captive Power Plant at Renusagar Power Division, Sonbhadra, Uttar Pradesh, India, in order to meet the present emission standard, set by MOEF for SO<sub>x</sub> control, which is < 600 mg/Nm<sup>3</sup> at 6 % O<sub>2</sub> dry. The design incorporates provision for attaining SO<sub>x</sub> level of <200 mg/Nm<sup>3</sup> at 6% O<sub>2</sub> dry in future by adding more number of modules.

#### Design Basis FGD Plant

We have taken cognizance of the anticipated performance and actual performance data at BMCR and 100% TMCR and the above coal analysis provided by RENUAGAR CPP, namely, Oxygen and Flue Gas temperature at ESP inlet and outlet, and the following gas analysis to derive at the gas flow, temperature, SO<sub>x</sub> emissions to form the design basis of the FGD system offered.

#### Flue Gas Duct

Flue Gas Duct	KKS System Code: 50HTA	
Flow through ID fan individual discharge	m <sup>3</sup> /hr	293335
Flow in m <sup>3</sup> /s	m <sup>3</sup> /s	81.48
Gas temperature	DegC	148
Dimension of Individual duct selected	m x m	<b>1.8 x 3.6</b>
There shall be 02 No's such ducts from individual ID and discharge.		
Flow through Common duct to Booster Fan suction*(Flow to match Booster Fan)	m <sup>3</sup> /s	163.0
Flow velocity considered	m/s	12.6
Dimension of BF suction duct selected	m x m	<b>3.6 x 3.6</b>
Flow through Common duct of Booster Fan discharge	m <sup>3</sup> /s	157.4
Flow velocity considered	m/s	<b>15.5</b>
Diameter of Booster Fan discharge duct selected	m	<b>3.6</b>
Flow through MCU	m <sup>3</sup> /s	157.4
Velocity considered through MCU	m/s	4.92
Dimension of MCU duct selected (Depth x width x height)	m x m x m	<b>4 x 8.0 x 15.0</b>



Owner:  
HINDALCO INDUSTRIES LIMITED  
Ahura Centre, 1st Floor, B Wing, Mahakali Caves Road, Andheri (East), Mumbai - 400 093, India



EPCM Contractor:  
W. L. GORE & ASSOCIATES (Pacific) Pte, Ltd. India Branch  
703, A-Wing, 215 Atrium, Andheri Kurla Road, Mumbai 400059, India

Hindalco Renusagar U5 1 x 80 MW PF Captive Power Plant  
Flue Gas Desulfurization Project (FGD) with GORE™ SO<sub>2</sub> Control System

### FGD-Technical Specification with Equipment Sizing

Client Doc.: S21001-TS01 -05HSD- 227201  
GORE Doc.: RPDU5.PG.001  
Rev.: 00 dated 10/03/2022  
File: FGD- Technical Specification with Equipment Sizing

### Fan System

Booster Fan	1 x 100% MCR	KKS Identification	50HSC10AN001		
Medium handled	Flue Gas – Analysis (% by Volume, wet): CO <sub>2</sub> – 10.8; O <sub>2</sub> – 6.62; N <sub>2</sub> -72.73; Moisture – 9.84. Flue Gas with dust concentration of 120 mg/Nm3 and SOx level- 1246 mg/Nm <sup>3</sup>				
Type	Centrifugal, Double Suction – Single Outlet, simply supported, backward bladed impeller, Motor driven. Fan inlet / outlet orientation shall be as per tender layout as per Annexure.				
Control of Fan	VFD as primary & RVC or MLD (Pneumatic Actuated) as secondary.				
Max. Speed	~990 RPM				
Basic Design Parameter					
Cases		100% BMCR(Present)	Fan Design (Present)	100% BMCR(Future)	Fan Design (Future)
Volume flow	m <sup>3</sup> /hr.	5,86,669.00	6,45,350.00	5,86,669.00	6,45,350.00
		Above flow figures are at (-) 25 mmwc and 148 °C			
Temperature	°C	148	148	148	148
Static Pressure at Duct tapping point	mm WC	(- )25	(- )25	(- )25	(- )25
Static Pressure at Fan I/L	mm WC	(- )60	(- )67	(- )60	(- )67
Static Pressure at Fan O/L	mm WC	(+)206	(+)249	(+)238	(+)289
Fan Differential	mm WC	266	316	298	356
Site Barometric Pr.	mmHg	736	736	736	736



Owner:  
HINDALCO INDUSTRIES LIMITED  
Ahura Centre, 1st Floor, B Wing, Mahakali Caves Road, Andheri (East), Mumbai - 400 093, India



EPCM Contractor:  
W. L. GORE & ASSOCIATES (Pacific) Pte, Ltd. India Branch  
703, A-Wing, 215 Atrium, Andheri Kurla Road, Mumbai 400059, India


Hindalco Renusagar U5 1 x 80 MW PF Captive Power Plant  
Flue Gas Desulfurization Project (FGD) with GORE™ SO<sub>2</sub> Control System

### FGD-Technical Specification with Equipment Sizing

Client Doc.: S21001-TS01 -05HSD- 227201  
GORE Doc.: RPDU5.PG.001  
Rev.: 00 dated 10/03/2022  
File: FGD- Technical Specification with Equipment Sizing

### FGTR (Flue Gas Treatment Reactor)

The Flue Gas Treatment Reactor (FGTR) is stacked with layers of Gore™ SPC catalyst modules arranged in 165 stacks with a maximum of 22 vertical layers (inclusive of 5 of catalyst management layers), arranged with a maximum of 5 vertical layers per stack in series, for SO<sub>x</sub> capture with sufficient space for future addition of layers. The gas velocity through the modules will be designed to a maximum of 2.2 mtr/ sec.



FGTR Module Description	FGTR KKS No: 50HSD10BA001	
No. of stacks	Nos	165
Stack Arrangement	Nos	11 x 15
No. of layers	Nos	15 to 22
No of layers for future case	Nos	27
No. of modules	Nos	2475 to 3630
Module Weight (Dry)	kg / module	40
Module Weight (Wet)	kg / module	80
Module Wet Weight Variability	%	± 10%

Flue gas flow (before cooling)	Nm <sup>3</sup> /h, wet	3,79,591
Flue gas flow (after cooling)	Nm <sup>3</sup> /h, wet	4,01,991
Flue gas flow	Am <sup>3</sup> /h	5,86,669
Inlet Temperature	°C	148
Operating Temperature	°C	53
SO <sub>2</sub> inlet conc.	mg/Nm <sup>3</sup> , dry @6% O <sub>2</sub>	1,590
SO <sub>2</sub> inlet conc.	mg/Nm <sup>3</sup> , dry	1,446
SO <sub>2</sub> inlet conc.	mg/Nm <sup>3</sup> , wet	1,246
SO <sub>2</sub> outlet conc.	mg/Nm <sup>3</sup> , dry @6% O <sub>2</sub>	500
SO <sub>2</sub> outlet conc.	mg/Nm <sup>3</sup> , dry	455
SO <sub>2</sub> outlet conc.	mg/Nm <sup>3</sup> , wet	392
SO <sub>2</sub> Efficiency	%	65%
GSCS Module Pressure Drop	Pa/layer	65
GSCS Total Pressure Drop	Pa	1430
Acid dewpoint	°C	64



Owner:  
HINDALCO INDUSTRIES LIMITED  
Ahura Centre, 1st Floor, B Wing, Mahakali Caves Road, Andheri (East), Mumbai - 400 093, India




EPCM Contractor:  
W. L. GORE & ASSOCIATES (Pacific) Pte, Ltd. India Branch  
703, A-Wing, 215 Atrium, Andheri Kurla Road, Mumbai 400059, India

Hindalco Renusagar U5 1 x 80 MW PF Captive Power Plant  
Flue Gas Desulfurization Project (FGD) with GORE™ SO<sub>2</sub> Control System

### FGD-Technical Specification with Equipment Sizing

Client Doc.: S21001-TS01 -05HSD- 227201  
GORE Doc.: RPDU5.PG.001  
Rev.: 00 dated 10/03/2022  
File: FGD- Technical Specification with Equipment Sizing



TYPICAL FGTR & WET STACK



Owner:  
HINDALCO INDUSTRIES LIMITED  
Ahura Centre, 1st Floor, B Wing, Mahakali Caves Road, Andheri (East), Mumbai - 400 093, India



EPCM Contractor:  
W. L. GORE & ASSOCIATES (Pacific) Pte, Ltd. India Branch  
703, A-Wing, 215 Atrium, Andheri Kurla Road, Mumbai 400059, India

Hindalco Renusagar U5 1 x 80 MW PF Captive Power Plant  
Flue Gas Desulfurization Project (FGD) with GORE™ SO<sub>2</sub> Control System

**FGD-Technical Specification with Equipment Sizing**

Client Doc.: S21001-TS01 -05HSD- 227201  
GORE Doc.: RPDU5.PG.001  
Rev.: 00 dated 10/03/2022  
File: FGD- Technical Specification with Equipment Sizing

**MCU (Mist Cooling Unit)**

The centrifugal booster fan of the unit will discharge the total flue gas to the Mist Cooling Unit (MCU) where the flue gas will be conditioned by spray water cooling to a saturation point with Relative Humidity close to 100% saturation. The gas temperature at the outlet is expected to be at circa 53 °C after the Mist Cooling Unit. After the Mist Cooling Unit (MCU), the saturated flue gas will enter the Reactor Tower via flow streamliners for SO<sub>x</sub> capture.

Mist Cooling Unit	KKS No: 50HTH10AC001	
Flue gas vol flow rate to MCU	M <sup>3</sup> /hr	566640
Flue gas temp at inlet to MCU	deg C	148
Temp after MCU	deg C	53.0
Water required to be added to achieve saturation	M <sup>3</sup> /hr	22.0
Blowdown from MCU	M <sup>3</sup> /hr	7.00
Water flow required at MCU inlet	M <sup>3</sup> /hr	29.0
Margin on Flow	%	32



Owner:  
HINDALCO INDUSTRIES LIMITED  
Ahura Centre, 1st Floor, B Wing, Mahakali Caves Road, Andheri (East), Mumbai - 400 093, India




EPCM Contractor:  
W. L. GORE & ASSOCIATES (Pacific) Pte, Ltd. India Branch  
703, A-Wing, 215 Atrium, Andheri Kurla Road, Mumbai 400059, India

Hindalco Renusagar U5 1 x 80 MW PF Captive Power Plant  
Flue Gas Desulfurization Project (FGD) with GORE™ SO<sub>2</sub> Control System

### FGD-Technical Specification with Equipment Sizing

Client Doc.: S21001-TS01 -05HSD- 227201  
GORE Doc.: RPDU5.PG.001  
Rev.: 00 dated 10/03/2022  
File: FGD- Technical Specification with Equipment Sizing





Owner:  
HINDALCO INDUSTRIES LIMITED  
Ahura Centre, 1st Floor, B Wing, Mahakali Caves Road, Andheri (East), Mumbai - 400 093, India



EPCM Contractor:  
W. L. GORE & ASSOCIATES (Pacific) Pte, Ltd. India Branch  
703, A-Wing, 215 Atrium, Andheri Kurla Road, Mumbai 400059, India

Hindalco Renusagar U5 1 x 80 MW PF Captive Power Plant  
Flue Gas Desulfurization Project (FGD) with GORE™ SO<sub>2</sub> Control System

### FGD-Technical Specification with Equipment Sizing

Client Doc.: S21001-TS01 -05HSD- 227201  
GORE Doc.: RPDU5.PG.001  
Rev.: 00 dated 10/03/2022  
File: FGD- Technical Specification with Equipment Sizing

## FGD & SAC Plant Process & Storage tanks

<b>PWT (Process Water Tank) tank storage capacity calculation</b>	<b>50GNK13BB002</b>		<b>FWT (Fresh Water Tank) tank storage capacity calculation</b>	<b>50PBL10BB001</b>	
Design Code	IS	803	Design Code	IS	803
Media	-	0.25% H <sub>2</sub> SO <sub>4</sub>	Media	-	Fresh Water
Storage volume provided	M <sup>3</sup>	50	Storage volume provided	M <sup>3</sup>	25.00
Diameter considered	m	~4.50	Diameter considered	m	~3.00
Height calculated	m	~3.90	Height calculated	m	~3.90
Height provided	m	~3.60	Height provided	m	~3.60
<b>FGTR Effluent Storage tank capacity calculation</b>	<b>50HSM34BB004</b>		<b>SAC Recovered Water Tank storage capacity calculation</b>	<b>50GNE10BB005</b>	
Design Code	IS	803	Design Code	IS	803
Media	-	10% H <sub>2</sub> SO <sub>4</sub>	Media	-	0.25% H <sub>2</sub> SO <sub>4</sub>
Storage volume provided	M <sup>3</sup>	50.00	Storage volume provided	M <sup>3</sup>	50.00
Diameter considered	m	~4.50	Diameter considered	m	~4.50
Height calculated	m	~3.90	Height calculated	m	~3.90
Height provided	m	~3.60	Height provided	m	~3.60
<b>95% H<sub>2</sub>SO<sub>4</sub> STORAGE Tank capacity calculation</b>	<b>50GNE20BB006</b>		<b>Overhead Emergency Tank</b>	<b>50PBL20BB003</b>	
Design Code	IS	803	Design Code	IS	803
Media	-	95% H <sub>2</sub> SO <sub>4</sub>	Media	-	Fresh Water
Storage volume provided	M <sup>3</sup>	50.00	Storage volume provided	M <sup>3</sup>	5
Diameter considered	m	~4.50	Diameter considered	m	~2.00
Height calculated	m	~3.90	Height calculated	m	~2.00
Height provided	m	~3.60	Height provided	m	~2.60





Owner:  
HINDALCO INDUSTRIES LIMITED  
Ahura Centre, 1st Floor, B Wing, Mahakali Caves Road, Andheri (East), Mumbai - 400 093, India



EPCM Contractor:  
W. L. GORE & ASSOCIATES (Pacific) Pte, Ltd. India Branch  
703, A-Wing, 215 Atrium, Andheri Kurla Road, Mumbai 400059, India

Hindalco Renusagar U5 1 x 80 MW PF Captive Power Plant  
Flue Gas Desulfurization Project (FGD) with GORE™ SO<sub>2</sub> Control System

### FGD-Technical Specification with Equipment Sizing

Client Doc.: S21001-TS01 -05HSD- 227201  
GORE Doc.: RPDU5.PG.001  
Rev.: 00 dated 10/03/2022  
File: FGD- Technical Specification with Equipment Sizing

### FGD & SAC Plant Process & Storage Pumps

Fresh water Pump	50PBL11AP003		FGTR EFFLUENT Transfer Pump	50HSM21AP009	
	50PBL12AP004			50HSM22AP010	
Pump capacity calculated	M³/hr	40	Pump capacity calculated	M³/hr	12
Flow	M³/hr	36	Flow	M³/hr	4.81
Head	mmWC	65	Head	mmWC	50
Process water Pump	50GNK14AP001		PUMP TO CLIENT Services	50GNK11AP010	
	50GNK15AP002			50GNK12AP011	
Pump capacity calculated	M³/hr	36	Pump capacity calculated	M³/hr	15
Flow	M³/hr	29	Flow- Continuous	M³/hr	7
Head	mmWC	160	Flow- Intermittent	M³/hr	14.1
FGTR Module Wash Pump	50HSM11AP005		Head	mmWC	35
	50HSM12AP006				
Pump capacity calculated	M³/hr	100			
Flow	M³/hr	71.5-91.3			
Head	mmWC	70			